

The Automation People
PROLIFIC Prolific Systems & Technologies Pvt. Ltd.
 ISO 9001 : 2008 & ISO 14001 : 2004



Login Database Connection



User ID :

Password :

✓
 OK

✗
 Cancel

i
 Prolific

[Change Password](#)

MATPro

New Motor Test

Conduct The Test

Auto Manual

Select Pole

Machine Name

Winder Name

Enter Excise No.

OK Close

Rating : 3.75 - AC
KW : 3.75
Volt : 415
HP : 5

Meter Configuration

New Motor Test

Core Loss Test

Core Type

Core Inside Diameter mm

Slot Depth mm

Back - Iron Depth mm

Mean Diameter mm

Test Current Amp

Measured Current Amp

Measured Voltage Volt

PF

Core Loss Watt

Frequency Hz

Excise No.

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

Edit Motor Test

Conduct The Test

Auto Manual

Select Pole

Excise No.

OK Close

Rating : 3.75 - AC
 KW : 3.75
 Volt : 415
 HP : 5

Meter Configuration

- Select All**
- Routine Test**
 - Measurement of Winding Resistance Test
 - High Voltage Test
 - Insulation Resistance Test
 - No Load Loss Test
 - Lock Rotor Test
 - Core Loss Test

- Type Test**
 - Cold Efficiency
 - Temperature Rise Test
 - Full Load Torque
 - Hot Efficiency
 - Load Loss Test
 - Load Curve Test
 - Friction and Windage Loss Test
 - Reduce Voltage Test
 - Momentary Overload Test
 - Over Speed Test
 - Break Down Torque
 - Vibration Test
 - Surge Test
 - Noise Level Test

Next

New Motor Test

Excise No.

OK Close

Rating : 3.75 - AC
 KW : 3.75
 Volt : 415
 HP : 5

Meter Configuration

Resistance Test

Unit

Ambient Temperature (°C)

RY Phase	YB Phase	BR Phase

New Motor Test

Excise No.

123



OK



Close

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

High Voltage Test

Applied Voltage (kV)

Leakage Current (mA)



Save



Acquire



Close



Delete

New Motor Test

Excise No.

123



OK



Close

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

Insulation Resistance Test

Insulation Resistance (Coil To Earth) (MΩ)



Save



Acquire



Close



Delete

New Motor Test

Excise No.

123



OK



Close

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

No Load Loss Test

%	Voltage (V)	Current (A)	PF	I/P (W)	Frequency (Hz)	Speed (RPM)
100						



Save



Acquire



Close



Delete

New Motor Test

Lock Rotor Test

Excise No.

V1	V2	V3	VAvg	I1	I2	I3	IAvg	W1	W2	W3	Loss	Frq [Hz]	PF	Torque [Nm]	Torque at Rated Voltage [Nm]
[Volts]				[Amps]				[Watts]							


OK Close

Rating : 3.75 - AC
 KW : 3.75
 Volt : 415
 HP : 5

Meter Configuration


New Motor Test

Temperature Rise Test

O/P kW :  Interval in (mins)

Time	Volt	Current	I/P kW	Freq.	RPM	O/P kW	Ambient Temp.	Body Temp.
14:04								
14:24								
14:44								

Excise No.

Rating : 3.75 - AC
 KW : 3.75
 Volt : 415
 HP : 5

Meter Configuration

Calculated Readings










New Motor Test

Temperature Rise Test

O/P kW :  Interval in (mins)

Time	Volt	Current	I/P kW	Freq.	RPM	O/P kW	Ambient Temp.	Body Temp.
14:04								
14:24								
14:44								

Excise No.

Rating : 3.75 - AC
 KW : 3.75
 Volt : 415
 HP : 5

Meter Configuration

Calculated Readings









New Motor Test

Excise No.

11



OK



Close

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

Load Loss Test

% Load	Volt (V)	Curr. (A)	Input (W)	Meas. Freq (Hz)	RPM	Slip (%)	Converted RPM	Output (W)	Eff. (%)	PF	Torque (NM)
25 %											
50 %											
75 %											
100 %											
115 %											
Pullout											

Calculated Readings



Add Row



Delete Row



Save



Acquire



Close



Delete

New Motor Test

Excise No.

11



OK



Close

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

Vibration Test

	H (mm/s)	V (mm/s)	A (mm/s)
DE Side			
NDE Side			



Save



Acquire



Close



Delete

New Motor Test

Excise No.



OK



Close

Rating : 3.75 - AC

KW : 3.75

Volt : 415

HP : 5

Meter Configuration

Noise Level Test

Noise Level (dB)



Save



Close



Delete